## SCOTTISH ENVIRONMENT PROTECTION AGENCY **POLLUTION PREVENTION AND CONTROL ACT 1999**

#### POLLUTION PREVENTION AND CONTROL (SCOTLAND) REGULATIONS 2012 ("THE REGULATIONS")

#### **NOTICE OF VARIATION TO PERMIT**

Permit No:

PPC/A/1013494 (As Varied)

To:

**ExxonMobil Chemical Limited** 

Address:

**Ermyn House Ermyn Way** Leatherhead **KT22 8UX** 

The Scottish Environment Protection Agency ("SEPA"), in exercise of its powers under Regulation 46 of the Regulations, hereby gives you notice that it has decided, to vary permit PPC/A/1013494 (As Varied) granted under the Regulations The variations are specified in the Schedule to this notice and take effect on 26 November 2019.

Scottish Environment Protection Agency

Date: 26 November 2019

Right of Appeal

Under Regulation 58 of the Regulations you are entitled to appeal to the Scottish Ministers against the conditions attached to this Notice, except where SEPA has served this Notice to implement a direction to SEPA of the Scottish Ministers. The bringing of an appeal will not have the effect of suspending the operation of the conditions attached to this Notice. The procedures and timescales for the making of an appeal are set out in Schedule 8 of the Regulations.



## SCOTTISH ENVIRONMENT PROTECTION AGENCY

## **POLLUTION PREVENTION AND CONTROL ACT 1999**

# POLLUTION PREVENTION AND CONTROL (SCOTLAND) REGULATIONS 2012 ("THE REGULATIONS")

### SCHEDULE TO NOTICE OF VARIATION UNDER REGULATION 46(8)

Operator:

**ExxonMobil Chemical Limited** 

Permit Number:

PPC/A/1013494 (As Varied)

Date of Permit:

29 October 2007

**Variation No:** 

**VN08** 

Permit number PPC/A/1013494 (As Varied) has been varied as follows

1. In the Interpretation of Terms, a new terms are added as follows:

"Start-up" and "shut-down" has the same meaning as in the Commission Implementing Decision (2012/249/EU), OJ L 334, 17.12.2000, p.17.

- 2. In Schedule 1, a new paragraph, 1.1.4.1 (g) is added as follows;
- 1.1.4.1 (g) 7 combustion plants, M146, M161, M162, M163, M164, M165 and M166, each having a net rated thermal input of 8.2 MWth and 2 fired super heaters, M174+M643 and M175+M644, each having a net thermal input of 1.5 MW, all using natural gas as a fuel.
  - 3. In Schedule 2, the following rows are inserted into Table 2.1:

Table 2.1 - Reporting and Notification Requirements

Summary of Information to be Reported or Notified	Condition	Date/Within period/ Frequency to be Reported	Date First Report Due
Measurement of emissions from combustion plants, M146, M161, M162, M163, M164, M165, M166, M174+M643 and M175+M644.	4.1.8	Within two weeks from first operation of plant	Within 7 days of being available.
Type and quantity of fuel use in combustion plants M146, M161, M162, M163, M164, M165, M166, M174+M643 and M175+M644	4.1.9	Recording only - for period of operation	Not applicable

4. In Schedule 4, the emission points A 20 to A 28 inclusive are added to Table 4.1 as follows as follows;

Table 4.1 – Emissions to Air ELVs

and	and the state of the state of	and the state of start Up then	Temporary   Temporary   Temporary   Doiler   (M162)	of         Stack         St	of         SS         SS<	Emission point number		Emission Stack height/diameter (m)	Type Monitoring	Details Sampling Location	Oxides Nitrogen mg/m³	fo	Farameters from Emission	Smoke	
A20 Temporary boiler (M146) Solution Stack		A21 Temporary boiler (M161) Ss 8.2/0.8 Stack 100 100 Ringelmann Shade 2 > 30mins at Start Up then Ringelmann Shade 2 > 100 then Ringelmann Shade 2 > 100 then Ringelmann Ringelm	A21 A22 Temporary boiler (M162) boiler (M161) (M162) SS SS SS SS Stack Stack 100 100 100 100 Ringelmann Shade 2 > 30mins at Start Up then then Ringelmann	A21 A22 A23  Temporary Temporary Doiler (M161) boiler (M162) (M163) (M161) (M162) (M163)  8.2/0.8 8.2/0.8 8.2/0.8  Stack Stack Stack Stack  100 100 100  Ringelmann Ringelmann Shade 2 > 30mins at Start Up then then then Ringelmann R	A21         A22         A23         A24           Temporary boiler (M161)         Temporary boiler boiler (M162)         Temporary boiler boiler (M164)         M164)           8.2/0.8         8.2/0.8         8.2/0.8         8.2/0.8           8.2/0.8         8.2/0.8         8.2/0.8           Stack         Stack         Stack           Stack         Stack         Stack           Stack         Stack         Stack           Shade 2 > 30mins at Start Up then then then then then then then then	umber	-	neight/ sr (m)		gr n	100000	9			No.
	A21 Temporary boiler (M161) SS 8.2/0.8 Stack 100 100 Shade 2 > 30mins at Start Up then Ringelmann Shade 2 > 100 then Ringelmann Ringelma		A22 Temporary boiler (M162) S2 S2 Stack 100 T00 Stack Stade 2 > 30mins at Start Up then Ringelmann Start Up then Ringelmann	A22 A23  Temporary Temporary boiler (M162) (M163)  8.2/0.8  8.2/0.8  8.2/0.8  Stack Stack  100 100 100 100 Shade 2 > 30mins at Start Up then then then Ringelmann Ringelmann Shade 2 > 30mins at Start Up then Ringelmann	A22         A23         A24           Temporary boiler (M162)         Temporary boiler (M164)         M164)           boiler (M162)         (M163)         (M164)           8.2/0.8         8.2/0.8         8.2/0.8           Ss         SS         SS           Stack         Stack         Stack           100         100         100           100         100         100           Shade 2 > 30mins at Start Up then then then then then then then then	A20	Temporary boiler (M146)	8.2/0.8	SS	Stack	200		Ringelmann Shade 2 >	30mins at Start Up	Ringelmann
A23         A24         A25           Temporary boiler (M163)         Temporary boiler (M165)         Temporary boiler (M165)           8.2/0.8         8.2/0.8         8.2/0.8           Ss         SS         SS           Stack         Stack         Stack           100         100         100           Ringelmann Shade 2 > 30mins at Start Up then then Ringelmann	Temporary Temporary boiler (M164) (M165)  8.2/0.8 8.2/0.8  Stack Stack  Stack Stack  Too 100  Too 30mins at Shade 2 > 30mins at Start Up then then Ringelmann	A25 Temporary boiler (M165) Solution 100 Temporary boiler (M165) Sack Stack Stack Stack Stack The Start Up then then Ringelmann		A26 Temporary boiler (M166) Solution 100 Stack Stack Stack Stack Stack Stack Start Up then then Ringelmann		A27	Temporary fired super- heater (M174+M643)	9.9/0.6	SS	Stack	100	а	Ringelmann Shade 2 >	Start Up then	Ringelmann
A23         A24         A25         A26           Temporary boiler (M163)         Temporary Doiler (M165)         Temporary Doiler (M166)         (M164)         (M165)         (M166)         <	A24	A25 A26  Temporary Temporary boiler (M165) (M166) (	A26 Temporary boiler (M166) (M166) (S20.8 Stack Stack Too Too Stack Stark Shade 2 > 30mins at Start Up then then Ringelmann Ringelmann Shade 2 > 30mins at Start Up then Ringelmann		A27 Temporary fired superheater (M174+M643) 8.9/0.6 Stack 100 100 Stack Stack Stack Stack Stack Then Ringelmann Shade 2 > 30mins at Start Up then	A28	Temporary fired super- heater (M175+M644)	9.0/6.6	SS	Stack	100	ä	Ringelmann Shade 2 >	Start Up then	Ringelmann

5. In Schedule 4, the following rows are added to Table 4.2;

Table 4.2 - Emissions to Air Monitoring Requirements

		Spot Sampling (SS)				
Parameter	Emission point number	Standard	Frequency	Operational Mode		
Oxides of Nitrogen	A20 to A28	Direct measurement using Flue Gas Analyser	6 monthly	Operating under stable conditions at a representative even load;  Not undergoing start-up or shut-down;		
Carbon Monoxide	A20 to A28	Direct measurement using Flue Gas Analyser	6 monthly	Operational		
Smoke	A20 to A28	BS 2742:1969	Start Up / Shut Down	Start Up/ Shut Down		
		12	Daily	Operational		
Oxygen %	A20 to A28	Direct measurement using Flue Gas Analyser	6 monthly	Operational		

6. In Schedule 4, the following rows are added to Table 4.3;

Table 4.3 - Reference Conditions

Emission Point Number	Reference Condition
A20 to A28 inclusive	Dry, 273K, 101.3kPa, Oxygen 3%v/

- 7. In Schedule 4, a new conditions 4.1.7 to 4.1.9 are added as follows:
- 4.1.7 All reasonable steps must be taken to ensure periods of start-up and shut-down of combustion plants, M146, M161, M162, M163, M164, M165, M166, M174+M643 and M175+M644 are kept as short as possible.
- 4.1.8 The first measurement of emissions from combustion plants, M146, M161, M162, M163, M164, M165, M166, M174+M643 and M175+M644 must be taken within two weeks from the first operation of each combustion plant and submitted to SEPA within 7 days of being available.
- 4.1.9 Records must be kept of the type and quantity of fuel use in combustion plants M146, M161, M162, M163, M164, M165, M166, M174+M643 and M175+M644.

