

SCOTTISH ENVIRONMENT PROTECTION AGENCY

POLLUTION PREVENTION AND CONTROL ACT 1999

POLLUTION PREVENTION AND CONTROL (SCOTLAND) REGULATIONS 2012

Schedule to a Notice requiring further information served under paragraph 7 of Schedule 4 to the Pollution Prevention and Control (Scotland) Regulations 2012 on FCC Waste Services (UK) Ltd in respect of application reference number PPC/A/1136072.

Column 1 (Information Required)	Column 2 (Date Information Required)
<u>1. Planning Permission</u> Please provide confirmation and evidence that detailed planning permission has been approved by the Local Authority.	01 July 2015
<u>2. Air Quality</u> Additional information justifying the impact of the plant on the air quality standard for NO _x in the area surrounding the plant, and specifically the Musselburgh AQMA should be provided.	05 June 2015
<u>3. Heat and Power Plan</u> a) Please provide a definition of the CHPQA site boundary as described in the SEPA Thermal Treatment of Waste Guidelines 2014. b) Additional information on the assumptions and working behind the Heat and Power Plan calculations should be provided to SEPA.	05 June 2015
<u>4. Noise Mitigation BAT Assessment</u> Your application refers to noise mitigation measures that will be incorporated into the plant and gives some examples of potential techniques and equipment. Please provide details of these measures, or if not yet available, the proposed measures. Please also include a BAT assessment to ensure that potential noise issues are designed out or minimised from the plant.	05 June 2015
<u>5. Initial Site Condition and Baseline Reports</u> Please provide an assessment of the substances that will be used on site in accordance with SEPA Site and baseline Report Guidance (IED TG02). This should assess their properties against Article 3 of the Hazardous Substance Regulation. This assessment should be used to determine the need for a baseline report (which would be required under a Pre Operating Condition, if necessary).	05 June 2015

6. FCC Lincoln Monitoring

Please provide the three quarterly extractive monitoring reports referenced in your application for the FCC Lincoln EfW plant.

05 June 2015